

용량[kW]별 배선용차단기 정격전류[A] 선정표

[3상440V, 3상480V]

부하전력 [Kw]	3상440V		3상480V	
	계산전류 [A]	차단기 [A]	계산전류 [A]	차단기 [A]
3	4.37	6	4.01	6
4	5.83		5.35	
5	7.29	10	6.68	10
6	8.75		8.02	
7	10.21	15	9.36	15
8	11.66		10.69	
9	13.12		12.03	
10	14.58		13.36	
11	16.04	20	14.70	20
12	17.50		16.04	
13	18.95		17.37	
14	20.41	30	18.71	30
15	21.87		20.05	
16	23.33		21.38	
17	24.79		22.72	
18	26.24		24.06	
19	27.70		25.39	
20	29.16		26.73	
21	30.62	40	28.07	40
22	32.08		29.40	
23	33.53		30.74	
24	34.99		32.08	
25	36.45	50	33.41	50
26	37.91		34.75	
27	39.36		36.08	
28	40.82		37.42	
29	42.28		38.76	
30	43.74		40.09	
31	45.20		41.43	

용량[kW]별 배선용차단기 정격전류[A] 선정표

[3상440V, 3상480V]

부하전력 [Kw]	3상440V		3상480V	
	계산전류 [A]	차단기 [A]	계산전류 [A]	차단기 [A]
32	46.65	50	42.77	50
33	48.11		44.10	
34	49.57		45.44	
35	51.03	60	46.78	
36	52.49		48.11	
37	53.94		49.45	
38	55.40		50.79	60
39	56.86		52.12	
40	58.32		53.46	
41	59.78		54.79	
42	61.23	75	56.13	
43	62.69		57.47	75
44	64.15		58.80	
45	65.61		60.14	
46	67.07		61.48	
47	68.52		62.81	
48	69.98	100	64.15	75
49	71.44		65.49	
50	72.90		66.82	
51	74.36		68.16	
52	75.81		69.50	100
53	77.27		70.83	
54	78.73		72.17	
55	80.19		73.51	
56	81.65		74.84	
57	83.10	100	76.18	100
58	84.56		77.51	
59	86.02		78.85	
60	87.48		80.19	

용량[kW]별 배선용차단기 정격전류[A] 선정표

[3상440V, 3상480V]

부하전력 [Kw]	3상440V		3상480V	
	계산전류 [A]	차단기 [A]	계산전류 [A]	차단기 [A]
61	88.94	100	81.52	100
62	90.39		82.86	
63	91.85		84.20	
64	93.31		85.53	
65	94.77		86.87	
66	96.23		88.21	
67	97.68		89.54	
68	99.14		90.88	
69	100.60	125	92.22	125
70	102.06		93.55	
71	103.51		94.89	
72	104.97		96.23	
73	106.43		97.56	
74	107.89		98.90	
75	109.35		100.23	
76	110.80		101.57	
77	112.26		102.91	
78	113.72		104.24	
79	115.18		105.58	
80	116.64		106.92	
81	118.09		108.25	
82	119.55		109.59	
83	121.01		110.93	
84	122.47		112.26	
85	123.93	150	113.60	
86	125.38		114.94	
87	126.84		116.27	
88	128.30		117.61	
89	129.76		118.94	

용량[kW]별 배선용차단기 정격전류[A] 선정표

[3상440V, 3상480V]

부하전력 [Kw]	3상440V		3상480V	
	계산전류 [A]	차단기 [A]	계산전류 [A]	차단기 [A]
90	131.22	150	120.28	125
91	132.67		121.62	
92	134.13		122.95	
93	135.59		124.29	
94	137.05		125.63	150
95	138.51		126.96	
96	139.96		128.30	
97	141.42		129.64	
98	142.88		130.97	
99	144.34		132.31	
100	145.80		133.65	
101	147.25		134.98	
102	148.71		136.32	
103	150.17	175	137.66	150
104	151.63		138.99	
105	153.09		140.33	
106	154.54		141.66	
107	156.00		143.00	
108	157.46		144.34	
109	158.92		145.67	
110	160.38		147.01	
111	161.83		148.35	
112	163.29		149.68	
113	164.75		151.02	175
114	166.21		152.36	
115	167.66		153.69	
116	169.12		155.03	
117	170.58		156.37	
118	172.04		157.70	

용량[kW]별 배선용차단기 정격전류[A] 선정표

[3상440V, 3상480V]

부하전력 [Kw]	3상440V		3상480V	
	계산전류 [A]	차단기 [A]	계산전류 [A]	차단기 [A]
119	173.50	175	159.04	175
120	174.95		160.38	
121	176.41	200	161.71	
122	177.87		163.05	
123	179.33		164.38	
124	180.79		165.72	
125	182.24		167.06	
126	183.70		168.39	
127	185.16		169.73	
128	186.62		171.07	
129	188.08		172.40	
130	189.53		173.74	200
131	190.99	225	175.08	
132	192.45		176.41	
133	193.91		177.75	
134	195.37		179.09	
135	196.82		180.42	
136	198.28		181.76	
137	199.74		183.09	
138	201.20		184.43	
139	202.66		185.77	
140	204.11		187.10	
141	205.57		188.44	
142	207.03		189.78	
143	208.49		191.11	
144	209.95		192.45	
145	211.40		193.79	
146	212.86		195.12	
147	214.32		196.46	

용량[kW]별 배선용차단기 정격전류[A] 선정표

[3상440V, 3상480V]

부하전력 [Kw]	3상440V		3상480V	
	계산전류 [A]	차단기 [A]	계산전류 [A]	차단기 [A]
148	215.78	225	197.80	200
149	217.24		199.13	
150	218.69		200.47	225
151	220.15		201.81	
152	221.61		203.14	
153	223.07		204.48	
154	224.53		205.81	
155	225.98	250	207.15	
156	227.44		208.49	
157	228.90		209.82	
158	230.36		211.16	
159	231.81		212.50	
160	233.27		213.83	
161	234.73		215.17	
162	236.19		216.51	
163	237.65		217.84	
164	239.10		219.18	
165	240.56		220.52	
166	242.02		221.85	
167	243.48		223.19	
168	244.94		224.53	
169	246.39		225.86	250
170	247.85		227.20	
171	249.31		228.53	
172	250.77	300	229.87	
173	252.23		231.21	
174	253.68		232.54	
175	255.14		233.88	
176	256.60		235.22	

용량[kW]별 배선용차단기 정격전류[A] 선정표

[3상440V, 3상480V]

부하전력 [Kw]	3상440V		3상480V	
	계산전류 [A]	차단기 [A]	계산전류 [A]	차단기 [A]
177	258.06	300	236.55	250
178	259.52		237.89	
179	260.97		239.23	
180	262.43		240.56	
181	263.89		241.90	
182	265.35		243.24	
183	266.81		244.57	
184	268.26		245.91	
185	269.72		247.24	
186	271.18		248.58	
187	272.64		249.92	
188	274.10		251.25	300
189	275.55		252.59	
190	277.01		253.93	
191	278.47		255.26	
192	279.93		256.60	
193	281.39		257.94	
194	282.84		259.27	
195	284.30		260.61	
196	285.76		261.95	
197	287.22		263.28	
198	288.68		264.62	
199	290.13		265.96	
200	291.59		267.29	